

*My copy to Jim Kelly
TMC / M...
DWPC*

Div file

Copy 4/23/84

*#11902002
MADISON*

EAST ALTON / OLIN CORP



EAST ALTON, ILLINOIS 62024

April 9, 1984

CERTIFIED MAIL

Director
Illinois Environmental Protection Agency
2200 Churchill Road
Springfield, Illinois 62706

EPA Region 5 Records Ctr.



382813

Dear Sir:

In compliance with Title 35, Subtitle G, Chapter 1, Part 725.156(j), the following summarizes an incident which occurred involving an interim status hazardous waste facility:

- | | |
|--|---|
| 1. Name, Address, and Telephone Number of Owner | Olin Corporation
Shamrock Street
East Alton, IL 62024
(618) 258-2000 |
| 2. Name, Address, and Telephone Number of Facility | Olin Corporation
Main Plant Facility
U.S. I.D.# ILD006271696

Remaining information same as above. |
| 3. Date, Time and Type of Incident | Discharge of a RCRA hazardous waste from a treatment facility's wastewater lifting station that overflowed due to a clogged sewer discharge line.

Spill began at approximately 8:00 a.m. on 4/3/84 and lasted about 2 hours. |
| 4. Name and Quantity of Material Involved | Approximately 300 gallons of untreated wastewater (K044). |
| 5. Extent of Injuries | None. |
| 6. Assessment of Actual or Potential Hazards to Human Health or the Environment. | Impact on human health and the environment estimated to be negligible. |

RECEIVED

APR 17 1984

E.P.A. - D.L.P.C.
STATE OF ILLINOIS

7. Estimated Quantity and Disposition
of Recovered Material that Resulted
from the Incident.

Approximately 300 gallons of free standing
untreated wastewater was vacuumed up
from the area of spillage and pumped
back into a separate process sewer line.

Approximately 7 cubic yards of
contaminated soil was excavated and
disposed of at a hazardous waste
landfill.

To comply with Part 725.156(j), a copy of this and other reports
associated with this incident will be attached to the operating record for
this hazardous waste facility.

Should you have any questions regarding this report, please do not
hesitate to contact this office.

Very truly yours,



L.W. Maxson, Director
Energy & Environmental Services

Attachment
WJG/tec

cc: Regional Administrator
Region V
U.S. Environmental Protection Agency
230 South Dearborn Street
Chicago, IL 60604

RECEIVED

APR 17 1984

E.P.A. — D.L.P.C.
STATE OF ILLINOIS